

Klassenhäufigkeitsverteilung



Tagesverteilung Konzentration von
Jahresverteilung Konzentration von
Parameterstand

09.05.2011 00:00:00 bis 09.05.2011 24:00:00
Klassierungsbeginn bis 09.05.2011 24:00:00
03.03.2011 09:47:29 V 4.19

Anlagenname	HKW 1		HKW 1		HKW 1		HKW 1		HKW 1		HKW 1	
Kanalname	Staub		SO2		CO		Volumen		SO2_Roh		SAG	
Grenzwert	100.000		350.000		100.000		1000000.000		100.000		95.000	
Einheit	mg/Nm3		mg/Nm3		mg/Nm3		m3/h		mg/Nm3		%	
Klassierungs- beginn	01.01.11	01.01.11	01.01.11	01.01.11	01.01.11	01.01.11	01.01.11	01.01.11	01.01.11	01.01.11	01.01.11	01.01.11
	00:00:00	00:00:00	00:00:00	00:00:00	00:00:00	00:00:00	00:00:00	00:00:00	00:00:00	00:00:00	00:00:00	00:00:00
Klzs	09.05.2011	24:00:00	24:00:00	24:00:00	24:00:00	24:00:00	24:00:00	24:00:00	24:00:00	24:00:00	24:00:00	24:00:00
	Jahr	Tag	Jahr	Tag	Jahr	Tag	Jahr	Tag	Jahr	Tag	Jahr	Tag
M 1	0	0	17657	144	0	0	6118	48	5884	48		
M 2	0	0	0	0	0	0	0	0	1	0		
M 3	0	0	0	0	0	0	0	0	0	0		
M 4	0	0	1	0	0	0	0	0	303	0		
M 5	5815	48	0	0	0	0	0	0	0	0		
M 6	115	0	0	0	0	0	0	0	0	0		
M 7	158	0	910	0	221	0	0	0	0	0		
M 8	22	0	0	0	68	0	0	0	0	0		
M 9	23	0	0	0	4285	18	0	0	0	0		
M 10	12	0	0	0	1614	30	0	0	0	0		
M 11	10	0	0	0	0	0	0	0	0	0		
M 12	12	0	0	0	0	0	0	0	0	0		
M 13	18	0	0	0	0	0	0	0	0	0		
M 14	3	0	0	0	0	0	0	0	0	0		
M 15	0	0	0	0	0	0	0	0	0	0		
M 16	0	0	0	0	0	0	0	0	0	0		
M 17	0	0	0	0	0	0	0	0	0	0		
M 18	0	0	0	0	0	0	0	0	0	0		
M 19	0	0	0	0	0	0	0	0	0	0		
M 20	0	0	0	0	0	0	0	0	0	0		
S 1 Überschreitung	0	0	0	0	0	0	0	0	0	0		
S 2 < 2/3	1	0	0	0	1	0	72	0	1	0		
S 3 Mit Ersatzwert	70	0	0	0	70	0	0	0	0	0		
S 4 Störung	0	0	0	0	0	0	70	0	0	0		
S 5 Wartung	0	0	0	0	0	0	0	0	0	0		
S 6 Betriebszeit	6190	48	18569	144	6190	48	6190	48	6190	48		
S 7 < 2/3 Anlage	1	0	0	0	1	0	1	0	1	0		
S 8 unplaus.Werte	0	0	0	0	0	0	1	0	0	0		
S 9 Wert>Kal./Anz	0	0	0	0	0	0	0	0	0	0		
S 10 Wochen>Kal.	0	0	0	0	0	0	0	0	0	0		
S 11 Ausf.ARE	0	0	0	0	0	0	0	0	0	0		
S 12	0	1	0	1	0	1	0	0	0	1		
S 13 Ausf.ARE Jahr	3	0	1	0	3	0	0	0	3	0		
S 14 An/Abfahren	0	0	0	0	0	0	0	0	0	0		
Tagesgrenzwert	100.00		350.00		100.00		1000000.00		100.00		95.00	
T 1	0	0	122	1	0	0	129	1	122	1	0	0
T 2	0	0	0	0	0	0	0	0	1	0	0	0
T 3	0	0	1	0	0	0	0	0	0	0	0	0
T 4	0	0	0	0	0	0	0	0	6	0	0	0
T 5	116	1	0	0	0	0	0	0	0	0	0	0
T 6	7	0	0	0	0	0	0	0	0	0	0	0
T 7	5	0	6	0	4	0	0	0	0	0	0	0
T 8	0	0	0	0	2	0	0	0	0	0	0	0
T 9	0	0	0	0	97	0	0	0	0	0	0	0
T 10	1	0	0	0	26	1	0	0	0	0	0	0
TS 1 Überschreitung	0	0	0	0	0	0	0	0	0	0	129	1
TS 2 kein TMW	0	0	0	0	0	0	0	0	0	0	0	0
TS 3 kein TMW WA/ST	0	0	0	0	0	0	0	0	0	0	0	0
TS 4 SAG <= GW											0	0
TS 5 SAG > GW											129	1
Tageskonzentration	47.72		0.00		90.03		0.00		0.00		0.00	
Monatskonzentration	47.93		0.00		89.99		0.00		0.00		0.00	
Jahreskonzentration	48.95		11.78		85.76		0.00		1.53		0.00	
Einheit	kg		kg		kg		--		kg		--	
Tagesemission	0.00		0.00		0.00		0.00		10906.14		0.00	
Monatsemmission	29.23		0.00		46.20		0.00		124405.20		0.00	
Jahresemission	1965.01		0.00		1436.93		0.00		3335525.00		0.00	

D-ER500 Systemdatei



Anlage : Energie
Daten vom : 09.05.2011

Datum **Zeit**

09.05.11 24:00:00 Jahresverfügbarkeit: 99.98%
09.05.11 24:00:00 Betriebszeit: Energie_ Betrieb 24:00:00

D-ER500 Sonderklassen

Anlage : Energie
Daten vom : 09.05.2011



Datum	Zeit	Kanal	Text			
09.05.11	24:00:00	SAG Sonderkl.	TMW	TS 1	0.000	%